



# TEST REPORT

1. NO : CT19-066718

2. Client

○ Name : LUFTT KOREA INC.

○ Address : 8F, Hanyang Tower, 12, Beobwon-ro 11-gil, Songpa-gu, Seoul Republic of Korea, 05836

Reissuance(R1)

Date : 2020.10.16

3. Date of Test : 2019.06.05 ~ 2019.07.31

4. Use of Report : Quality control

5. Test Sample : Air Purifier(LFT105)

6. Test Method

(1) SPS-KACA002-132:2018

7. Test Results

1) Air Purifier(LFT105)

Test Item(s)	Unit	Test Method	Test Results	Remark
Clean Air Delivery Rate	m <sup>3</sup> /min	(1)	7.5	(20 ± 1) °C, (45 ± 5) % R.H.
Usage Area	m <sup>2</sup>	(1)	58.0	(20 ± 1) °C, (45 ± 5) % R.H.

\* Operation mode : 4th(Rated Air Flow Rate)

Affirmation	Tested By	Technical Manager
	Name : Seongkoo Cho	Name : Sang Kyun Park



Our report apply only to the standards or procedures identified and to the sample(s) tested unless otherwise specified. The test results are not indicative of representative of the qualities of the lot from which the sample was taken or of apparently identical or similar products. The authenticity of this test report can be checked on KCL website(www.kcl.re.kr).

2019.07.31

Korea Conformity Laboratories President Yoon, Kap Seok *Yoon, Kap Seok*

Address : 08503 199, Gasan digital 1-ro, Geumcheon-gu, Seoul, Korea 82-2-2102-2500

Result Inquiry : Electric & Electronic Center 82-32-728-5515



# TEST REPORT

No : CT19-066718



— End of Report —

