



# TEST REPORT

1. NO : CT18-122972

2. Client

○ Name : LUFTT KOREA INC.

○ Address : 8F, Hanyang Tower, 12, Beobwon-ro 11-gil, Songpa-gu, Seoul Republic of Korea, 05836

3. Date of Test : 2018.11.20 ~ 2019.01.24

4. Use of Report : Quality control

5. Test Sample : LUFTT LHC102

6. Test Method

(1) KS C 9325:2011

Reissuance(R1)
Date : 2020.10.16

7. Test Results

1) LUFTT LHC102

Test Item(s)	Unit	Test Method	Test Results	Remark
Particle Efficiency	%	(1)	96.1	(21 ± 1) °C, (45 ± 5) % R.H.
Initial Pressure Drop	Pa	(1)	40.2	(21 ± 1) °C, (45 ± 5) % R.H.

\* Rated Air Flow Rate : 2.5 m<sup>3</sup>/min

\* Test sample size : (233 \* 250) mm

\* Duct size : (300 \* 300) mm



Affirmation	Tested By Name : Seongkoo Cho	Technical Manager Name : Sang Kyun Park
Our report apply only to the standards or procedures identified and to the sample(s) tested unless otherwise specified. The test results are not indicative of representative of the qualities of the lot from which the sample was taken or of apparently identical or similar products. The authenticity of this test report can be checked on KCL website(www.kcl.re.kr).		

2019.01.24

Korea Conformity Laboratories President Yoon, Kap Seok *Yoon, Kap Seok*

Address : 08503 199, Gasan digital 1-ro, Geumcheon-gu, Seoul, Korea 82-2-2102-2500

Result Inquiry : Electric & Electronic Center 82-32-728-5515



# TEST REPORT

No : CT18-122972



----- End of Report -----

